Stanford Synchrotron Radiation Laboratory

LCLS Room Data Sheet #	1.9-1050	Central Lab Office Complex (CLOC) - Accelerator Scientists & Designers Pod	Revision 2
Javier A. Sevilla Owner / Editor Jim Welch	Signa	## Date	
itional Facilities System Physicist	Signa	ature Date	
David Saenz Conventional Facilities System Manager	Moving Signa	Sizios  ature Date	
Stefan Moeller X-R End stations WBS Manager	Slifan Mon	08/12/05 ature Date	
John Arthur Photon Beam System Manager	Signa	8-12-05 ature Date	
Darren Marsh Quality Assurance Manager	Signa	ature Date	

## **REVISION INFORMATION**

Rev 2- Updated floor plan, deleted mechanical humidification, updated Standards and Codes. General corrections

RDS 1.9-1050-R2 Central Lab Office Complex ACCELERATOR SCIENTISTS DESIGNERS POD

## **ROOM DATA SHEETS**

FACILITY COMPONENT	CLOC ACCELER	ATOR SCIENTISTS/DI	ESIGNER	POD - ROOM DATA SHE	ET			
	Name of Building		Accelerator Scientists & Designer Pod					
	Organization or Departme	nt	SLAC, Stanford University					
	Net area		219.0	sq. meters	2352SF			
	Critical dimensions		H:		12'-0"			
			W:		varies			
			L:		varies			
	Hours of operation		Normal b	ousiness hours				
	Users/Occupancy		Workers within the CLOC that are assigned private "systems-cubicle workstations. Occupancy Group "B"					
	Building orientation		Accelerat	tor Scientists & Designer Pod is located	d on the third floor.			
FUNCTIONAL OBJECTIVE	Provide conveniently located	d office space with maximum flexit	oility for emplo	oyees working in the CLOC.				
PLANNING CONSIDERATIONS & CRITICAL FACTORS	1 - Office space in the Acce workstations.	lerator Scientists & Designer Pod	pod shall cons	sist of (8) 10'x10' staff offices and (10)	8'x8' systems furniture			
FINISHES	Walls	Painted framed gypsum boa	rd assembly (	(color: white)				
	Ceiling			d acoustic tile ceiling assembly.				
	Floor	Carpet						
	Base	Rubber base						
	Doors	NA						
	Fenestration	When cubicle are located ad	ljacent to the	exterior window, the lower window unit	shall be operable.			
	Acoustical	Typical office decibel level re	equired NC les	ss 35 Excessive white noise is not des	sired.			
APPLICABLE STANDARDS	29 CFR Part 1910 Occupational Safety and Health Standards Dept of Labor, 29 CFR Part 1926 Safety and Health Regulations for Constructions Dept of Labor, Uniform Building Code (UBC) 1997 including appendixes, National Electric Code (NEC) 2002, Uniform Mechanical Code (UMC) 2003 including appendixes, Uniform Plumbing Code (UPC) 2003 including appendixes, Uniform Fire Code (UFC) 2003 including appendixes, California Code of Regulations Title 8 Industrial Safety, Title 19 Public Safety, NFPA 70 National Fire Codes, National electrical Safety Code ANSI C2, Occupational Safety and Health Act (OSHA), General Services Administration 41 CFR part 101-19, American with Disabilities Act, Environmental Protection Agency 40 CFR Parts 264 and 265, SLAC Environmental Safety & Health Manual, General Industrial Activities Storm Water Permit (SLAC Permit), NFPA 101 life Safety Code, Title 24-energy Code, DOE standard 10 CFR Part 435, ASHRAE/IES Standards 90.1, NFPA Standard 13 and SLAC Fire Marshal requirements, LCLS Cabling Standard, SLAC LOTO							

VIEWS & SCHEMATICS (N. T. S.)			Fi	gure No. 1			
ACCELERATOR SCIENTISTS & DESIGNERS OFFICE POD							
MECHANICAL REQUIREMENTS	HVAC		Heating system	Temp: 70 degrees F <u>+</u> 3 degree F		Mechanical humidification	
		×	Air conditioning	Temp: 74 degrees F+ 3 degree F		Direct exhaust system - for laser table experiment enclosures only.	
			Direct supply Indirect supply			Positive pressure system Negative pressure system	
			Smoke control system	od to		Standard registers	
			Temperature sensors connect SLAC's DDC systems	eu เบ		Requirement for gases	

	Communications	×	Telephone- 2 phone		PA speakers		
	Communications		lines/location-see comments  Dataport- 2 jacks/location-see				
		×	comments		PA station		
			Payphone		CCTV camera		
		X	Fire alarm station		CCTV monitor		
			Intercom				
				.li			
	Plumbing/Fire Protection		Hot water system		Electric watercooler		
			Cold water system		Drinking fountain		
			Tempered water	×	Smoke detection system		
			Waste drain	×	Standard sprinkler heads		
			Floor drain Trench drain		Eye wash / Safety shower		
			pmments: ectric watercooler shall be located in commo	on spa	ce conveniently located on the floo	or level, one per floor	
ELECTRICAL REQUIREMENTS	Power supply	208 volts, 3 phase outlets Uninterrupted power supply					
		X	110V 1ph, 20 amps outlets		Special electric	Туре:	
			Emergency power				
	Comments:						
	Lighting	×	Light fixtures - 2 x 4 recessed florescent lighting.		Remote lighting control		
			Fixture type I: Downlight	×	Light switches		
			Fixture type II: Bollard (exterior)	×	Lighting level	FC: typ. Office per IES	
		×	Emergency lighting				
	Comments: 1- Utilize standard Illuminating Engineering Society (IES) guidelines						
RADIATION/SEISMIC/VIBRATIONS ISSUES	Comments:  1- All equipment and systems are to be seismically braced and restrained SLAC Seismic Standards						
SPECIAL REQUIREMENTS FOR EQUIPMENT	Comments:						

CHEMICALS / GASES	CHEMICALS			SPECIALTY GASES			
		#	Chemical Type	Quantity	#	Gas Type	Quantity
ENVIRONMENTAL NEEDS							